

Arequa Gulch 115 kV Capacitor Bank Project

Project Sponsor:	Black Hills Colorado Electric
Additional Project Participants:	
Project Description:	A 12 MVAR switched shunt capacitor at the Arequa Gulch 115 kV substation for voltage support due to increased load growth.
Voltage Class:	115 kV
Facility Rating:	12 MVAR
Point of Origin/Location:	Arequa Gulch 115 kV (near Cripple Creek, CO)
Point of Termination:	
Intermediate Points:	
Length of Line (in Miles):	
Type of Project:	Substation
Development Status:	Planned
Routing:	
Subregional Planning Group:	CCPG
Purpose of Project:	Improved voltage support and reliability in the Cripple Creek area.
Estimated Cost (in 2013 Dollars):	\$900,000
Schedule:	
Construction Date:	2018
Planned Completion/In-Service Date:	2018
Regulatory Info:	Approved - Colorado PUC: Decision No. C15-0590
Regulatory Date:	
Permitting Info:	
Permitting Date:	
Contact Information:	Wes Wingen
Email	wes.wingen@blackhillscorp.com
Phone	605-721-2268